



REPUBLIC OF THE PHILIPPINES
PRESIDENTIAL COMMUNICATIONS OFFICE
NATIONAL PRINTING OFFICE



📍 EDSA corner NIA North Road, Diliman, Quezon City ✉ records@npo.gov.ph 📘 facebook.com/OfficialNPO

BIDS AND AWARDS COMMITTEE
Supplemental/ Bid Bulletin (SBB)
September 24, 2024

Subject: SUPPLY, DELIVERY, AND INSTALLATION OF ONE (1) LOT DIRECT EXPANSION LONG PIPE 4.0 TR CEILING MOUNTED INVERTER TYPE FAN COIL UNIT [Identification No. NPO-BAC-019-24]

This Supplemental / Bid Bulletin is issued to amend, respond to any written clarifications /request, and other matters relative to the public bidding for the **SUPPLY, DELIVERY, AND INSTALLATION OF ONE (1) LOT DIRECT EXPANSION LONG PIPE 4.0 TR CEILING MOUNTED INVERTER TYPE FAN COIL UNIT [Identification No. NPO-BAC-019-24]**

The modifications, amendments, or clarifications are as follows:

- I. Queries/ Questions raised during the Pre-bid Conference held on 17 September 2024 by Prospective Bidders:

SECTION/ CLAUSE/ FORM AFFECTED	ORIGINAL	AMENDED
Section V. Special Conditions of Contract		
GCC Clause 1 Workmanship and Other Standards	-XXX- -XXX- -XXX- -XXX- -XXX- -XXX- -XXX- <i>All pipes, fitting and cables shall be embedded into the walls or to be concealed.</i>	-XXX- -XXX- -XXX- -XXX- -XXX- -XXX- -XXX- <u>All exposed piping outside the building must be concealed or clad using a G.I Sheet or any other approved material in accordance with regulations.</u>
Section VI. Schedule of Requirements		
Delivered Weeks/ Months	<i>To be delivered within Thirty (30) calendar days from issuance of Purchase Order</i>	To be delivered within Forty- five (45) calendar days from issuance of Purchase Order

SECTION/ CLAUSE/ FORM AFFECTED	ORIGINAL	AMENDED
	<i>(PO) / Notice to Proceed (NTP).</i>	<i>(PO) / Notice to Proceed (NTP).</i>

II. Clarifications received thru email by the BAC Secretariat:

QUERIES/ QUESTIONS	CLARIFICATIONS / RESPONSE
<p><i>Capacity Increase:</i></p> <p><i>"Can we offer a higher capacity unit, such as upgrading from 4 TR to 5 TR? "</i></p>	<p><i>Upgrade or changing in capacity is not allowed.</i></p>
<p><i>Delivery and Installation Timeframe:</i></p> <p><i>"Regarding the current 30-calendar day timeline for the delivery and installation of the 38 units, would it be acceptable to extend this to 45 calendar days to ensure smooth completion of the project?"</i></p>	<p>To be delivered within <u>Forty-five (45)</u> calendar days from issuance of Purchase Order (PO) / Notice to Proceed (NTP).</p>

III. This shall be an integral part of the Bidding Documents and the same shall be enclosed in the technical bid envelope/ components and shall be signed by the bidder accordingly.

IV. Bidders not complying with the above instructions shall be declared ineligible.

For the information and guidance of all concerned.

Issued this 24th day of September 2024.


ATTY. ARJAY C. LIM
 BAC Chairperson